

CANTON, CITY OF



Consumer Confidence Report – 2026

Covering Calendar Year – 2025



This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call MORGAN MORGAN at 620-628-4916.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). Your water comes from Ground water.

Source Name	Source Water Type
CC01 FROM MARION CO RWD 4	Ground water
CC02 FROM MARION CO RWD 4	Ground water
WELL 07	Ground water
WELL 10	Ground water
WELL 11	Ground water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.


Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems. In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 2 sample(s) per month in accordance with the Revised Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of

disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2025 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2025. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**



Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: CANTON, CITY OF

Regulated Contaminants	Collection Date	Highest Value	Range (Low/high)	Unit	MCL	MCLG	Typical Source
ARSENIC	5/1/2025	8.6	8.6	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM	1/23/2023	0.26	0.26	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	1/23/2023	3.2	3.2	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	1/23/2023	0.28	0.28	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	7/8/2025	11	8 - 11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM	1/23/2023	20	20	ppb	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Additional Required Health Effects Language:

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	2/15/2022	1.07	1.07	PCI/L	5	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	2/15/2022	4	4	PCI/L	15	0	Erosion of natural deposits
RADIUM-226	2/15/2022	1.07	1.07	PCI/L	5	0	Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	506 N MAIN	2025	8	8.4 - 8.4	ppb	60	0	By-product of drinking water disinfection
TTHM	506 N MAIN	2025	38	38 - 38	ppb	80	0	By-product of drinking water chlorination

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Lead and Copper	Monitoring Period	90TH Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2024	0.0772	0.026 - 0.65	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2024	0	0 - 33	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **CANTON, CITY OF** is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact **CANTON, CITY OF** at **620-628-4916**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

The Lead and Copper rules require water systems to develop and maintain a Service Line Inventory. The service line is the underground pipe that supplies your home or building with water. To view the Service Line Inventory, which lists the material type(s) for your location, you may view the inventory at: **100 S Main St, Canton KS 67428**.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
12/1/2025 - 12/31/2025	2.00000	MG/L	1.10000	MG/L

Secondary Contaminants – Non-Health Based Contaminants - No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	1/23/2023	260	260	MG/L	300
ALUMINUM	1/14/2020	0.024	0.024	MG/L	0.05
CALCIUM	1/23/2023	250	250	MG/L	200
CHLORIDE	1/23/2023	440	440	MG/L	250
CONDUCTIVITY @ 25 C UMHOS/CM	1/23/2023	1900	1900	UMHO/CM	1500
CORROSIVITY	1/14/2020	0.52	0.52	LANG	0
HARDNESS, TOTAL (AS CaCO3)	1/23/2023	720	720	MG/L	400
IRON	1/23/2023	0.02	0.02	MG/L	0.3
MAGNESIUM	1/23/2023	20	20	MG/L	150
MANGANESE	1/23/2023	0.025	0.025	MG/L	0.05
MANGANESE, DISSOLVED	4/12/2022	51.3	51.3	UG/L	0
NICKEL	1/23/2023	0.01	0.01	MG/L	0.1
PH	1/23/2023	7.4	7.4	PH	8.5
PHOSPHORUS, TOTAL	1/23/2023	1.8	1.8	MG/L	5
POTASSIUM	1/23/2023	4.9	4.9	MG/L	100
SILICA	1/23/2023	25	25	MG/L	50
SODIUM	1/23/2023	140	140	MG/L	100
SULFATE	1/23/2023	50	50	MG/L	250
TDS	1/23/2023	1300	1300	MG/L	500
ZINC	1/23/2023	0.013	0.013	MG/L	5

Additional Required Health Effects Language:

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

There are no additional required health effects violation notices.

Sample ID	Collection Date	Method	Analyte	Result
127459P	4/15/2025	EPA 200.7	lithium	43.3
129115R	5/20/2025	EPA 533	11CI-PF3OUdS	< MRL
129115R	5/20/2025	EPA 533	4:2 FTS	< MRL
129115R	5/20/2025	EPA 533	6:2 FTS	< MRL
129115R	5/20/2025	EPA 533	8:2 FTS	< MRL
129115R	5/20/2025	EPA 533	9CI-PF3ONS	< MRL
129115R	5/20/2025	EPA 533	ADONA	< MRL
129115R	5/20/2025	EPA 533	HFPO-DA	< MRL
129115R	5/20/2025	EPA 533	NFDHA	< MRL
129115R	5/20/2025	EPA 533	PFBA	< MRL
129115R	5/20/2025	EPA 533	PFBS	< MRL
129115R	5/20/2025	EPA 533	PFDA	< MRL
129115R	5/20/2025	EPA 533	PFDoA	< MRL
129115R	5/20/2025	EPA 533	PFEESA	< MRL
129115R	5/20/2025	EPA 533	PFHpA	< MRL
129115R	5/20/2025	EPA 533	PFHpS	< MRL
129115R	5/20/2025	EPA 533	PFHxA	< MRL
129115R	5/20/2025	EPA 533	PFHxS	< MRL
129115R	5/20/2025	EPA 533	PFMBA	< MRL
129115R	5/20/2025	EPA 533	PFMPA	< MRL
129115R	5/20/2025	EPA 533	PFNA	< MRL
129115R	5/20/2025	EPA 533	PFOA	< MRL
129115R	5/20/2025	EPA 533	PFOS	< MRL
129115R	5/20/2025	EPA 533	PFPeA	< MRL
129115R	5/20/2025	EPA 533	PFPeS	< MRL

Sample ID	Collection Date	Method	Analyte	Result
129115R	5/20/2025	EPA 533	PFUnA	< MRL
129115R	5/20/2025	EPA 537.1	NEtFOSAA	< MRL
129115R	5/20/2025	EPA 537.1	NMeFOSAA	< MRL
129115R	5/20/2025	EPA 537.1	PFTA	< MRL
129115R	5/20/2025	EPA 537.1	PFTTrDA	< MRL

Sample Event
SE2
Sample Schedule
Oct 2025
Facility ID
10001
Name
Treatment Plant (TP - 00198266)
Sample Point ID
EP001
Name
Finished Water Sample Tap at Point of entry (EP)
Schedule Comments
N/A

Sample ID	Collection Date	Method	Analyte	Result
133142P	10/13/2025	EPA 200.7	lithium	38.9
135539R	1/5/2026	EPA 533	11Cl-PF3OUdS	< MRL
135539R	1/5/2026	EPA 533	4:2 FTS	< MRL
135539R	1/5/2026	EPA 533	6:2 FTS	< MRL
135539R	1/5/2026	EPA 533	8:2 FTS	< MRL
135539R	1/5/2026	EPA 533	9Cl-PF3ONS	< MRL

Sample ID	Collection Date	Method	Analyte	Result
135539R	1/5/2026	EPA 533	ADONA	< MRL
135539R	1/5/2026	EPA 533	HFPO-DA	< MRL
135539R	1/5/2026	EPA 533	NFDHA	< MRL
135539R	1/5/2026	EPA 533	PFBA	< MRL
135539R	1/5/2026	EPA 533	PFBS	< MRL
135539R	1/5/2026	EPA 533	PFDA	< MRL
135539R	1/5/2026	EPA 533	PFDoA	< MRL
135539R	1/5/2026	EPA 533	PFEESA	< MRL
135539R	1/5/2026	EPA 533	PFHpA	< MRL
135539R	1/5/2026	EPA 533	PFHpS	< MRL
135539R	1/5/2026	EPA 533	PFHxA	< MRL
135539R	1/5/2026	EPA 533	PFHxS	< MRL
135539R	1/5/2026	EPA 533	PFMBA	< MRL
135539R	1/5/2026	EPA 533	PFMPA	< MRL
135539R	1/5/2026	EPA 533	PFNA	< MRL
135539R	1/5/2026	EPA 533	PFOA	< MRL
135539R	1/5/2026	EPA 533	PFOS	< MRL
135539R	1/5/2026	EPA 533	PFPeA	< MRL
135539R	1/5/2026	EPA 533	PFPeS	< MRL
135539R	1/5/2026	EPA 533	PFUnA	< MRL
		EPA 537.1	NtFOSAA	Missing
		EPA 537.1	NMeFOSAA	Missing
		EPA 537.1	PFTA	Missing
		EPA 537.1	PFTTrDA	Missing